

GARZ2.EX4631 - Clean Agents for Fire Extinguishers and Extinguishing System Units - Component

Clean Agents for Fire Extinguishers and Extinguishing System Units - Component

[See General Information for Clean Agents for Fire Extinguishers and Extinguishing System Units - Component](#)

3M COMPANY ELECTRONICS MATERIALS SOLUTIONS DIVISION
3M CENTER
SAINT PAUL, MN 55144 USA
Clean agent for fire extinguishers

EX4631

Model Designation	ASHRAE Designation
Type 3M™ Novec™ 1230 Fire Protection Fluid	FK-5-1-12mmy2

Clean agent for fire extinguishing system units

Model Designation	ASHRAE Designation	Flame Extinguishing Concentration for Class A Surface Burning Fuels, %	Flame Extinguishing Concentration for Class B Heptane Fuel, %
Type 3M™ Novec™ 1230 Fire Protection Fluid	FK-5-1-12mmy2	3.3	4.5

Marking: Company name or identification, product identification, UL Recognition Mark and type designation.

Last Updated on 2019-07-01

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"